ANDHRA PRADESH STATE LOAD DESPATCH CENTRE

From
Chief Engineer,
APSLDC,
Vidyut Soudha,
Gunadala, Vijayawada- 520 004.

To
The Executive Director,
RAC,PLG,EA & IPC,
APSPDCL,19-13-65/A,
Vidyut Nilayam, Srinivasapuram,Tirupati.

The Chief General Manager,
RAC,PPA &Solar Energy,
3rd Floor,APEPDCL,
Corporate office,P&T Colony,
Sethammadhara,Visakhapatnam-530013.

The Chief General Manager,
APCPDCL,Corporate office,
ITI Road,Vijayawada.

Lr. No. CE/SLDC/SE/GO/DEPPMO/DEE2/AEE-PP/F.Avail/D. No. 706/23, Dt.12 .01.2023

Sir,

Sub: APSLDC-Provisional Percentage cumulative availabilities/Capacity Index of APGENCO,APPDCL thermal Power stations and APGENCO Hydel stations up to the month of December 2022 for 2022–23 Communicated- Regarding.

* * * * *

The provisional percentage cumulative availabilities/Capacity Index of APGENCO ,APPDCL Thermal stations and APGENCO Hydel stations up to the month of December 2022 are attached herewith. It is requested to arrange for placing the availabilities in the Website as per Directive at Para No 117,page No.80 of APERC tariff order for the year 2022-23.

Encl: As above.

Yours faithfully,

Chief Engineer/APSLDC

Copy Communicated to CGM/Commercial/APTRANSCO/Vidyut Soudha/Vijayawada.
It is requested to arrange for placing the availabilities in the Websites as per Directive at para No 117,page No.80 of APERC tariff order for the year 2022-23.
Copy Communicated to the Chief Engineer/Commercial/APGENCO/Vidyut Soudha/Vijayawada.
Copy Communicated to CGM/APPDCL/Central Excise Colony/Road No.1/Andhra Loyola College road/Vijayawada-520004.
Copy Communicated to the Chief General Manager/Power Purchase/APPCC/Vidyut Soudha/Vijayawada.

Provisional Percentage availabilities/Capacity Index of APGENCO Thermal and Hydel stations for the Year 2022-23

	Thermal Stations								Hydel stations							
Station/Month	RTPP-1	RTPP-2	RTPP-3	RTPP-4	NTTS I TO III	NTTS-IV	K.Patnam, Stage-1	HNPCL	SSRB	Lower Sileru	Upper Sileru	Donkarayi	NSRC	Pennahobilam	Chettipeta	NSRTail Pond
Apr-22	87.66	74.13	57.80	72.82	86.98	96.71	47.85	41.65	--	100	100	94.77	100	--	100	100
May-22	70.70	81.36	81.72	73.72	81.99	94.19	41.20	59.69	--	99.14	100	99.96	100	--	--	100
Jun-22	64.10	94.46	85.19	58.79	73.28	98.05	25.66	50.65	--	100	100	100	100	--	100	71.03
Jul-22	37.92	93.41	84.90	70.72	66.21	48.56	43.90	54.39	99.64	100	100	100	100	--	100	80.7
Aug-22	53.55	82.87	83.79	15.26	57.48	70.11	51.32	62.84	99.20	100.00	94.62	100.00	100.00	100.00	100.00	70.76
Sep-22	74.00	90.84	78.87	20.69	59.21	77.45	51.48	53.66	99.30	100.00	100.00	100.00	100.00	100.00	100.00	88.31
Oct-22	60.74	67.50	78.64	62.89	50.42	82.02	31.44	45.50	98.06	100.00	100.00	100.00	100.00	100.00	100.00	100.00
Nov-22	48.27	29.48	77.60	60.08	56.31	82.25	38.51	67.45	98.67	100.00	100.00	100.00	100.00	100.00	100.00	100.00
Dec-22	42.00	97.39	85.46	75.04	69.60	69.54	42.69	48.96	99.98	100.00	100.00	100.00	100.00	100.00	100.00	100.00
Cumulative up to December 22 for FY 2022-23	**59.76**	**79.15**	**79.40**	**56.72**	**66.80**	**79.75**	**41.57**	**53.87**	**99.11**	**99.89**	**99.39**	**99.38**	**100.00**	**100.00**	**100.00**	**91.25**

CHIEF ENGINEER
APSLDC,VIDYUT SOUDHA
VIJAYAWADA